

ENVIRONMENTAL PROTECTION AGENCY

August 19, 1976

V.A. Hospital Lyons
Lyons, New Jersey 07939ENVIRONMENTAL PROTECTION AGENCY
REGION II, BUILDING 209
EDISON, NEW JERSEY 08817

Gentlemen:

We are undertaking a determination of compliance with 40 CFR, Part 112, "Oil Pollution Prevention Regulation," as published in the Federal Register, Volume 38, Number 237, dated December 11, 1973. Pursuant to Section 308 of the Federal Water Pollution Control Act Amendments ("the Act") of 1972, 33 U.S.C. Section 1251 et. seq., you are hereby required to provide EPA with answers to the questions listed below no later than September 2, 1976:

- (1) Does your facility store oil in any container with 660 gallon capacity or more?
- (2) What is your total above ground oil storage capacity?
- (3) What is your total underground oil storage capacity?
- (4) Have you had any spills at your facility within the past five years? If so, list the date of each spill, quantity spilled, and amount discharged into navigable waters or tributaries thereto.
- (5) Do you have a Spill Prevention Control and Countermeasure Plan, as required by 40 CFR, Part 112? If so, please provide a copy of the Plan.
- (6) On what date was your SPCC Plan fully implemented?

524320



SA/ERI:CKPrice/pan:Emer. Resp. Br.:Bldg. 209:X548:8/18/76

CONCURRENCES

SYMBOL	▶ CSA-EM							
SURNAME	▶ CKP							
DATE	▶ 8/19/76							

(7) If your SPCC Plan is not yet fully implemented, list what portions of your SPCC Plan have been implemented, and what portions remain outstanding. Give a projected time schedule for completion of all outstanding items.

(8) What is the name and telephone number of the owner and/or operator of your facility?

(9) Are any substances, other than oil, stored at your facility? If so, provide a listing by trade and chemical name of all liquid materials, by the pure compounds, mixtures thereof or solutions stored or having the capacity to be stored as set forth in (1), (2), and (3) above.

If the answers to these questions contain any information you consider proprietary or confidential, after answering the question, please so indicate. Failure to respond to the above questions by the date indicated above will subject you to the penalties provided for in Section 309 of the Act.

Your cooperation is greatly appreciated.

Sincerely yours,

Michael V. Polito
Chief, Emergency Response
& Inspection Branch

cc: William Mansfield, FFO